

SC 198 Sections in local application fire extinguishing systems

(June 2005)

(Corr.1
Sep 2022)

~~(Reg.II-2/10.5.6.3)~~

Interpretation of SOLAS chapter II-2 regulation 10.5.6.3 as amended by resolution MSC.338(91)

SOLAS Regulation II-2/10.5.6.3 reads as follows:

Fixed local application fire-extinguishing systems are to protect areas such as the following without the necessity of engine shutdown, personnel evacuation, or sealing of the spaces:

.1 the fire hazard portions of internal combustion machinery or, for ships constructed before 1 July 2014, the fire hazard portions of internal combustion machinery used for the ship's main propulsion and power generation; ~~the fire hazards portions of internal combustion machinery...~~

Interpretation

In multi-engine installations, at least two sections ~~should~~ shall be arranged.*

(* refer to item 3.2.4 of MSC.1/Circ.1387)

Note:

1. This Unified Interpretation is to be uniformly implemented by IACS Members and ~~Associates~~ on ships the keels of which are laid from 1 January 2006.

| |
|--------------------|
| End of Document |
|--------------------|