

F32

(1976)
(Rev.1
Aug 2026
Complete
Revision)

Manually Operated Call Points of Fire Detection and Fire Alarm Systems for Periodically Unattended Machinery Spaces

**Manual call points, unattended machinery spaces
(SOLAS Reg. II-2/7)**

This UR applies to ships certified in accordance with SOLAS chapter I.
(For ships not certified in accordance with SOLAS chapter I, see IACS Rec. 99)

For ships with periodically unattended machinery spaces, manually operated call points complying with the FSS Code are to be installed at passageways providing access to machinery spaces of category A and the engine control room.

Note:

1. Revision 1 of this UR is to be applied by IACS member societies to ships contracted for construction on or after 1 January 2028.
2. The “contracted for construction” date means the date on which the contract to build the vessel is signed between the prospective owner and the shipbuilder. For further details regarding the date of “contract for construction”, refer to IACS Procedural Requirement (PR) No. 29.

End of Document
