

GUIDANCE FOR THE SURVEY AND CONSTRUCTION OF STEEL SHIPS

Part R

Fire Protection, Detection and Extinction

Guidance for the Survey and Construction of Steel Ships

Part R

2013 AMENDMENT NO.2

Notice No.69 27th December 2013

Resolved by Technical Committee on 29th July 2013

Notice No.69 27th December 2013

AMENDMENT TO THE GUIDANCE FOR THE SURVEY AND CONSTRUCTION OF STEEL SHIPS

“Guidance for the survey and construction of steel ships” has been partly amended as follows:

Part R FIRE PROTECTION, DETECTION AND EXTINCTION

R30 SAMPLE EXTRACTION SMOKE DETECTION SYSTEMS

R30.2 Engineering Specifications

Paragraph R30.2.4 has been added as follows.

R30.2.4 System Control Requirements

With respect to the requirements of 30.2.4-1.(2), Part R of the Rules, the “CO2 Room” where the fire extinguishing medium (CO2) for a fixed gas fire-extinguishing system is stored with two separate CO2 control equipment complying with the provision of the requirements of Chapter 25, Part R of the Rules may be regarded as a fire control station.

EFFECTIVE DATE AND APPLICATION

1. The effective date of the amendments is 1 January 2014.