

Subject:

Reglation 18.7 of Chapter II-2
of SOLAS 1974 as amended

NK TECHNICAL INFORMATION

No.112

Date: 5th February 1993

TO : Shipowners and Shipbuilders concerned

In addition to the previous Technical Information No.108 dated 28th October 1992, we would like to inform you of the requirements of the following flag states for fire extinguishing arrangement in paint lockers and flammable liquid lockers.

1. Honduras : Only for existing ships
2. Kuwait : For new and existing ships
3. Malaysian : For new and existing ships, except East Malaysian ships
4. Philippine : For new ships
5. Indonesia : For new and existing ships

The requirements for existing ships were informed by the previous Technical Information.

Please refer to the attached table for details of requirements.

Your kind attention to the above would be greatly appreciated.

Attached : Table for the requirements of flag states Supplement - 1



Fire-extinguishing arrangements for paint lockers instructed by Flag States (No.2)

Supplement - 1

(As of 5th February, 1993)

Flag State	New Ship	Existing Ship
Honduras	Not finalized yet	One 9 lit. portable foam and one 4.6 kg CO ₂ portable fire extinguishers
Kuwait	- For lockers of floor space less than 4m² : Two portable CO₂ or dry powder fire extinguishers stowed outside to the access. - For lockers of floor area 4 m² or more Fixed (Note *3) - For lockers of floor space less than 15 m² : One non-portable CO₂ or dry powder with suitable size, permanently connected to a suitably located injection point may be substituted for the fixed installations referred to in above 2.	Same as new ship
Malaysia (Except East Malaysia)	- For tankers : Fixed (Note *3) - For ships other than tanker : - For lockers of floor space 10 m² and more: Fixed (Note *3) - For lockers of floor space less than 10 m² : Two portable 15lb CO₂ or 10lb dry powder fire extinguishers, stowed outside and adjacent to the access	- For tankers : Fixed (Note *3) Grace period : Until next docking - For ships other than tanker : Same as new ship
Philippine	- For lockers of floor space 20 m² or less : One portable 15lb CO₂ or 10lb dry powder fire extinguisher (Note *5) - For lockers of floor space over 20 m² or lockers for the ships of 20,000 GT and more carrying flammable liquid cargoes, e.g. oil tankers, chemical tankers and gas carriers : Fixed (Note *3)	Same as new ship Grace period (Note *6)
Indonesia	Portable fire extinguisher	Portable fire extinguisher

(Note *3), (Note *5) and (Note *6) : Please refer to the previous circular.